



# EXPLOSION PROTECTION

## CERTIFICATE OF CONFORMITY

Cert No. GYB24.2987X

|                         |                                                                                                         |
|-------------------------|---------------------------------------------------------------------------------------------------------|
| <b>Manufacturer</b>     | <b>SHANGHAI LEEG INSTRUMENTS CO.,LTD</b><br>(Address:No.99 DuhuiRoad, Minhang District, Shanghai China) |
| <b>Product</b>          | <b>Flameproof pressure transmitter</b>                                                                  |
| <b>Model</b>            | <b>2035 Series</b>                                                                                      |
| <b>Ex marking</b>       | <b>Ex db IIC T6 Gb,Ex tb IIIC T85°C Db</b>                                                              |
| <b>Product standard</b> | <b>Q/MS LG-Q-403-2023</b>                                                                               |
| <b>Drawing number</b>   | <b>2035-T/G-Ex</b>                                                                                      |

The product was found to comply with the following standard(s):

GB/T 3836.1-2021,GB/T 3836.2-2021,GB/T 3836.31-2021

**Valid until:** 2029.10.30

**Remarks**

- 1.Conditions for safe use are specified in the attachment to this certificate.
- 2.Symbol "X" placed after the certification number denotes specific conditions of use, which are specified in the attachment to this certificate.
- 3.Model designation is specified in the attachment to this certificate.

### Approval

**Shanghai Inspection and Testing Institute of  
Instruments and Automation Systems Co., Ltd.**  
**National Supervision and Inspection Center for  
Explosion Protection and Safety of Instrumentation**  
**Date of issue 2024.10.31**

This Certificate is valid for products compatible with the documents and samples approved by NEPSI.